

April 6, 2022

Westbury Water District
PWS ID No. NY2902856
MCL Deferral for 1,4-Dioxane, PFOA, and PFOS
Quarterly Report – First Quarter 2022

Introduction

On behalf of the Westbury Water District (WWD or District), D&B Engineers and Architects (D&B) has prepared this document in accordance with the requirements of the New York State Department of Health (NYSDOH) for public water suppliers who have been granted deferrals from Maximum Contaminant Level (MCL) violations for 1,4-Dioxane, Perfluorooctanoic Acid (PFOA), and/or Perfluorooctanesulfonic Acid (PFOS). The District was granted an MCL deferral for 1,4-Dioxane, PFOA, and PFOS in 2020. The WWD was granted a deferral because it has been proactive in its efforts to establish and implement an action plan for managing the above-referenced compounds.

The enclosed is a report describing the WWD's progress towards maintaining the highest quality of water for District customers and meeting the deadlines set forth in the deferral approval. Updated schedules for each project are contained in **Attachment A**.

Corrective Action Plan Milestones

Drexel Avenue Station – Wells 6 and 7A

The Drexel Ave Station (Wells 6 and 7A) Advanced Oxidation Process (AOP) project is currently under regulatory review. Regulatory review began with the submission of the engineering report to the Nassau County Department of Health (NCDH) and NYSDOH for review in the first quarter of 2021. Detailed design documents for the facility were submitted to the NCDH and NYSDOH for review in the third quarter of 2021. During the regulatory review period, comments and responses have been developed and exchanged. The regulatory review and approval process is taking longer than initially anticipated and, therefore, the project construction will be postponed until approvals are received to construct treatment.

Although it has been granted a deferral, the WWD was able to minimize the usage of these wells.

Well 12

The State Street (Well 12) PFOA and PFOS treatment project is currently under regulatory review. Regulatory review began with the submission of the engineering report to the NCDH and NYSDOH for review in the first quarter of 2021. Detailed design documents for the facility were submitted to the NCDH and NYSDOH for review in the third quarter of 2021. During the regulatory review period, comments and responses have been developed and exchanged. The regulatory review and approval process is taking

longer than initially anticipated and, therefore, the project construction will be postponed until approvals are received to construct treatment.

Although it has been granted a deferral, the District was able to avoid usage of this well.

Wells 10 and 14

The Wells 10 and 14 AOP project is currently under regulatory review. Approval of the engineering report has been received from the NCDH. The detailed design documents were submitted to the NCDH and NYSDOH in the first quarter of 2022. However, obtaining regulatory approval is taking longer than initially anticipated so, therefore, the project construction will be postponed until approvals are received to construct treatment.

Although it has been granted a deferral, the WWD was able to minimize the usage of these wells. It should be noted that only one of the two wells (Well 14) has exceeded the MCL for 1,4-dioxane.

Public Notification

In accordance with the terms of the deferral, the WWD has maintained an open line of communication with the public regarding its deferral. The deferral public notification documentation is still featured prominently on the District website, as are previous quarterly reports.

Analytical Sampling

Relevant sample results for the wells for which deferrals were granted (Wells 10, 12, and 14) taken during the first quarter of 2022 are contained in the below tables. Full laboratory reports for each sample are contained in **Attachment B**.

1,4-Dioxane (parts per billion, ppb)

Well	Date		
	January 2022	February 2022	March 2022
Well 6 (N-00101)	NS	NS	NS
Well 7A (N-07785)	NS	NS	NS
Well 10 (N-05007)	0.62	0.58	0.54
Well 14 (N-07353)	1.8	1.8	1.5

NS – not sampled due to wells being out of service

PFOA (parts per trillion, ppt)

Well	Date
	February 2022
Well 12 (N-05655)	12.9

PFOS (parts per trillion, ppt)

Well	Date
	February 2022
Well 12 (N-05655)	13.6

Conclusion

As demonstrated above, the Westbury Water District is actively working to preserve the quality of water for its customers and comply with the requirements put forth by the NYSDOH. The District looks forward to continuing to work towards completion of its treatment facilities.

Should you have any questions, please contact the District at 516-333-0427 or visit the website, www.westburywaterdistrict.com.

Very truly yours,

Board of Commissioners
Westbury Water District

Enclosures

cc: K. Wheeler (NYSDOH)
B. Rogers (NYSDOH)
W. Provoncha (NCDH)
P. Young (NCDH)
R. Putnam (NCDH)
J. Ingram (WWD)
B. Merklin (D&B)
P. Sachs (D&B)
L. Ortiz (D&B)
P. Connell (D&B)

ATTACHMENT A

Project Schedules Associated with MCL Deferral

Task Name	2022				2023				2024	
	Qtr 1	Qtr 2	Qtr 3	Qtr 4	Qtr 1	Qtr 2	Qtr 3	Qtr 4	Qtr 1	Qtr 2
Regulatory Review (In Progress)	■									
Construction			■							
Startup and Testing								■		



Task Name	2022				2023		
	Qtr 1	Qtr 2	Qtr 3	Qtr 4	Qtr 1	Qtr 2	Qtr 3
Regulatory Review (In Progress)	■						
Construction			■				
Startup and Testing						■	

Task Name	2022				2023				2024			
	Qtr 1	Qtr 2	Qtr 3	Qtr 4	Qtr 1	Qtr 2	Qtr 3	Qtr 4	Qtr 1	Qtr 2	Qtr 3	Qtr 4
Regulatory Review (In Progress)		█										
Construction						█						
Startup and Testing											█	



ATTACHMENT B

Water Quality Data



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70199547001
Client Sample ID.: N-05007

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 01/03/2022 07:50 AM Point N-05007
 Received : 01/03/2022 10:55 AM Location Well 10
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 01/05/2022 9:08 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.62	1		ug/L	1	01/05/2022 4:00 PM	001 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	97%		1	%REC		01/05/2022 4:00 PM	001 AG2R1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 01/06/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70199547002
Client Sample ID.: N-05654

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 01/03/2022 08:50 AM Point N-05654
 Received : 01/03/2022 10:55 AM Location Well 11
 Collected By CLIENT

<u>Analytical Method:</u> EPA 522		<u>Prep Method:</u> EPA 522			<u>Prep Date:</u> 01/05/2022 9:08 AM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,4-Dioxane (p-Dioxane)	0.57		1	ug/L	1	01/05/2022 4:35 PM	002 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	95%		1	%REC		01/05/2022 4:35 PM	002 AG2R1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 01/06/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70199547003
Client Sample ID.: N-07353

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 01/03/2022 08:10 AM Point N-07353
 Received : 01/03/2022 10:55 AM Location Well 14
 Collected By CLIENT

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	1.8*		1	ug/L	1	01/05/2022 5:10 PM	003 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	101%		1	%REC		01/05/2022 5:10 PM	003 AG2R1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 01/06/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70199547004
Client Sample ID.: N-08497

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 01/03/2022 07:30 AM Point N-08497
 Received : 01/03/2022 10:55 AM Location Well 16
 Collected By CLIENT

<u>Analytical Method:</u> EPA 522		<u>Prep Method:</u> EPA 522			<u>Prep Date:</u> 01/05/2022 9:08 AM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,4-Dioxane (p-Dioxane)	1.1*		1	ug/L	1	01/05/2022 5:27 PM	004 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	99%		1	%REC		01/05/2022 5:27 PM	004 AG2R1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 01/06/2022



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
70199547

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987
New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Virginia Certification # 460302

WO#: 70199547
70199547

Sample Request Form PUBLIC WATER SUPPLIER

Date: 1/3/2022

Collected By: M. Cabana

Accepted By: [Signature] 1/3/22 10:55

Cooler Temp: 1.4 °C

WELL OFF LINE

WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HCl

Client Info:
Name or Code: Westbury Water Dist.
Address:

Phone #:
Attn:
Proj. # or (Name):
Bill To:
Copies To:

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings		Analysis	Lab No.
						Cl ₂	pH/Temp		
1-3-2022 7:50 AM	GW	Well-10 N-05007	RW		RO			1.4 Dioxane	
1/3/22 8:50 AM	GW	Well-11 N-05654	RW		RO				
1/3/22 8:10 AM	GW	Well-14 N-07353	RW		RO				
1/3/22 7:30 AM	GW	Well-16 N-08497	RW		RO				

Remarks: 1-4 Dioxane.



Sample Condition Upon Receipt

WO#: 70199547

Client Name: WWD

Project

PM: JSA

Due Date: 01/12/22

CLIENT: WWD

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No N/A

Packing Material: Bubble Wrap Bubble Bags Ziploc Cone Other

Thermometer Used: TH091

Correction Factor: 0.00

Temperature Blank Present: Yes No

Type of Ice: Wet Blue None

Cooler Temperature (°C): 1.4

Cooler Temperature Corrected (°C): 1.4

Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: WWD 1/3/22

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

Table with 17 rows and 3 columns. Columns: Question, Yes/No/N/A, Comments. Includes items like Chain of Custody Present, Filtered volume received, pH paper Lot #, Residual chlorine strips, etc.

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205001
Client Sample ID.: N-02602

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 09:10 AM Point N-02602
 Received : 02/15/2022 01:23 PM Location Well 9
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 02/16/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	<0.020		1	ug/L	1	02/16/2022 7:57 PM	001 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	99%		1	%REC		02/16/2022 7:57 PM	001 AG2R1/2

Analytical Method: EPA 524.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Benzene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		02/26/2022 11:35	001 VG9C1/2
Bromoform	<0.50		1	ug/L		02/26/2022 11:35	001 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Chloroform	<0.50		1	ug/L		02/26/2022 11:35	001 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	02/26/2022 11:35	001 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205001
Client Sample ID.: N-02602

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 09:10 AM Point N-02602
 Received : 02/15/2022 01:23 PM Location Well 9
 Collected By CLIENT

Dibromochloromethane	<0.50	1	ug/L		02/26/2022 11:35	001 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	02/26/2022 11:35	001 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Styrene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Toluene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1	ug/L	80	02/26/2022 11:35	001 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	02/26/2022 11:35	001 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	02/26/2022 11:35	001 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	105%	1	%REC		02/26/2022 11:35	001 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	106%	1	%REC		02/26/2022 11:35	001 VG9C1/2

Analytical Method: EPA 537.1

Prep Method: EPA 537.1

Prep Date: 02/23/2022 5:37 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.9	1		ng/L		02/27/2022 10:30	001 BP3T1/2
Perfluoroheptanoic acid	<1.9	1		ng/L		02/27/2022 10:30	001 BP3T1/2
Perfluorohexanesulfonic acid	<1.9	1		ng/L		02/27/2022 10:30	001 BP3T1/2
Perfluorononanoic acid	<1.9	1		ng/L		02/27/2022 10:30	001 BP3T1/2
Perfluorooctanesulfonic acid	<1.9	1		ng/L	10	02/27/2022 10:30	001 BP3T1/2
Perfluorooctanoic acid	<1.9	1		ng/L	10	02/27/2022 10:30	001 BP3T1/2
Surr: 13C2-PFDA (S)	100%	1		%REC		02/27/2022 10:30	001 BP3T1/2
Surr: 13C2-PFHxA (S)	100%	1		%REC		02/27/2022 10:30	001 BP3T1/2
Surr: HFPO-DAS (S)	101%	1		%REC		02/27/2022 10:30	001 BP3T1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205001
Client Sample ID.: N-02602

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 09:10 AM Point N-02602
 Received : 02/15/2022 01:23 PM Location Well 9
 Collected By CLIENT

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 02/15/2022 7:15 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/16/2022 1:15 PM	001 SP5T1/1
Total Coliforms	Absent		1		Absent	02/16/2022 1:15 PM	001 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205002
Client Sample ID.: N-08497

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 09:25 AM Point N-08497
 Received : 02/15/2022 01:23 PM Location Well 16
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 02/16/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.72		1	ug/L	1	02/16/2022 8:15 PM	002 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	91%		1	%REC		02/16/2022 8:15 PM	002 AG2R1/2

Analytical Method: EPA 524.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,1-Dichloroethane	1.6		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,1-Dichloroethene	1.5		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Benzene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		02/26/2022 12:01	002 VG9C1/2
Bromoform	<0.50		1	ug/L		02/26/2022 12:01	002 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Chloroform	<0.50		1	ug/L		02/26/2022 12:01	002 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	02/26/2022 12:01	002 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205002
Client Sample ID.: N-08497

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 09:25 AM Point N-08497
 Received : 02/15/2022 01:23 PM Location Well 16
 Collected By CLIENT

Dibromochloromethane	<0.50	1	ug/L		02/26/2022 12:01	002 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	02/26/2022 12:01	002 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Styrene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Tetrachloroethene	0.69	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Toluene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1	ug/L	80	02/26/2022 12:01	002 VG9C1/2
Trichloroethene	0.70	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	02/26/2022 12:01	002 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	02/26/2022 12:01	002 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	110%	1	%REC		02/26/2022 12:01	002 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	104%	1	%REC		02/26/2022 12:01	002 VG9C1/2

Analytical Method: EPA 537.1

Prep Method: EPA 537.1

Prep Date: 02/23/2022 5:37 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.9	P4	1	ng/L		02/27/2022 10:46	002 BP3T1/2
Perfluoroheptanoic acid	<1.9	P4	1	ng/L		02/27/2022 10:46	002 BP3T1/2
Perfluorohexanesulfonic acid	<1.9	P4	1	ng/L		02/27/2022 10:46	002 BP3T1/2
Perfluorononanoic acid	<1.9	P4	1	ng/L		02/27/2022 10:46	002 BP3T1/2
Perfluorooctanesulfonic acid	<1.9	P4	1	ng/L	10	02/27/2022 10:46	002 BP3T1/2
Perfluorooctanoic acid	4.1	P4	1	ng/L	10	02/27/2022 10:46	002 BP3T1/2
Surr: 13C2-PFDA (S)	102%	1		%REC		02/27/2022 10:46	002 BP3T1/2
Surr: 13C2-PFHxA (S)	100%	1		%REC		02/27/2022 10:46	002 BP3T1/2
Surr: HFPO-DAS (S)	95%	1		%REC		02/27/2022 10:46	002 BP3T1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205002
Client Sample ID.: N-08497

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 09:25 AM Point N-08497
 Received : 02/15/2022 01:23 PM Location Well 16
 Collected By CLIENT

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 02/15/2022 7:15 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/16/2022 1:15 PM	002 SP5T1/1
Total Coliforms	Absent		1		Absent	02/16/2022 1:15 PM	002 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205003
Client Sample ID.: NB-9/16

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 09:35 AM Point NB-9/16
 Received : 02/15/2022 01:23 PM Location Wells 9 & 16
 Collected By CLIENT

<u>Analytical Method:</u> EPA 522		<u>Prep Method:</u> EPA 522			<u>Prep Date:</u> 02/16/2022 9:34 AM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,4-Dioxane (p-Dioxane)	0.52		1	ug/L	1	02/16/2022 8:32 PM	003 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	101%		1	%REC		02/16/2022 8:32 PM	003 AG2R1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 03/01/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205004
Client Sample ID.: N-05007

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 10:50 AM Point N-05007
 Received : 02/15/2022 01:23 PM Location Well 10
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 02/16/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.58		1	ug/L	1	02/16/2022 8:49 PM	004 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	96%		1	%REC		02/16/2022 8:49 PM	004 AG2R1/2

Analytical Method: EPA 524.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,1-Dichloroethane	1.4		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,1-Dichloroethene	1.6		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
Benzene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		02/26/2022 12:27	004 VG9C1/2
Bromoform	<0.50		1	ug/L		02/26/2022 12:27	004 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2
Chloroform	<0.50		1	ug/L		02/26/2022 12:27	004 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	02/26/2022 12:27	004 VG9C1/2

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205004
Client Sample ID.: N-05007

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 10:50 AM Point N-05007
 Received : 02/15/2022 01:23 PM Location Well 10
 Collected By CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Dibromochloromethane	<0.50	1		ug/L		02/26/2022 12:27	004 VG9C1/2
Dibromomethane	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Dichlorodifluoromethane	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Ethylbenzene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Methyl-tert-butyl ether	<0.50	1		ug/L	10	02/26/2022 12:27	004 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Styrene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Tetrachloroethene	3.5	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Toluene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1		ug/L	80	02/26/2022 12:27	004 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	02/26/2022 12:27	004 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	02/26/2022 12:27	004 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	109%	1		%REC		02/26/2022 12:27	004 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	108%	1		%REC		02/26/2022 12:27	004 VG9C1/2

Analytical Method: EPA 537.1

Prep Method: EPA 537.1

Prep Date: 02/23/2022 5:37 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.8	1		ng/L		02/27/2022 11:18	004 BP3T1/2
Perfluoroheptanoic acid	<1.8	1		ng/L		02/27/2022 11:18	004 BP3T1/2
Perfluorohexanesulfonic acid	<1.8	1		ng/L		02/27/2022 11:18	004 BP3T1/2
Perfluorononanoic acid	<1.8	1		ng/L		02/27/2022 11:18	004 BP3T1/2
Perfluorooctanesulfonic acid	<1.8	1		ng/L	10	02/27/2022 11:18	004 BP3T1/2
Perfluorooctanoic acid	<1.8	1		ng/L	10	02/27/2022 11:18	004 BP3T1/2
Surr: 13C2-PFDA (S)	102%	1		%REC		02/27/2022 11:18	004 BP3T1/2
Surr: 13C2-PFHxA (S)	99%	1		%REC		02/27/2022 11:18	004 BP3T1/2
Surr: HFPO-DAS (S)	97%	1		%REC		02/27/2022 11:18	004 BP3T1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205004
Client Sample ID.: N-05007

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 10:50 AM Point N-05007
 Received : 02/15/2022 01:23 PM Location Well 10
 Collected By CLIENT

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 02/15/2022 7:15 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/16/2022 1:15 PM	004 SP5T1/1
Total Coliforms	Absent		1		Absent	02/16/2022 1:15 PM	004 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205005
Client Sample ID.: N-07353

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 10:15 AM Point N-07353
 Received : 02/15/2022 01:23 PM Location Well 14
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 02/16/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	1.8*		1	ug/L	1	02/16/2022 9:07 PM	005 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	100%		1	%REC		02/16/2022 9:07 PM	005 AG2R1/2

Analytical Method: EPA 524.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,1,1-Trichloroethane	0.92		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,1-Dichloroethane	5.2*		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,1-Dichloroethene	1.7		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Benzene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Bromoform	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Chloroform	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	02/26/2022 12:53	005 VG9C1/2

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri
 Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205005
Client Sample ID.: N-07353

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 10:15 AM Point N-07353
 Received : 02/15/2022 01:23 PM Location Well 14
 Collected By CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Dibromochloromethane	<0.50	1		ug/L		02/26/2022 12:53	005 VG9C1/2
Dibromomethane	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Dichlorodifluoromethane	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Ethylbenzene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Methyl-tert-butyl ether	<0.50	1		ug/L	10	02/26/2022 12:53	005 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Styrene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Tetrachloroethene	0.51	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Toluene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1		ug/L	80	02/26/2022 12:53	005 VG9C1/2
Trichloroethene	1.5	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	02/26/2022 12:53	005 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	02/26/2022 12:53	005 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	102%	1		%REC		02/26/2022 12:53	005 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	103%	1		%REC		02/26/2022 12:53	005 VG9C1/2

Analytical Method: EPA 537.1

Prep Method: EPA 537.1

Prep Date: 02/23/2022 5:37 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.9	P4	1	ng/L		02/27/2022 11:02	005 BP3T1/2
Perfluoroheptanoic acid	<1.9	P4	1	ng/L		02/27/2022 11:02	005 BP3T1/2
Perfluorohexanesulfonic acid	<1.9	P4	1	ng/L		02/27/2022 11:02	005 BP3T1/2
Perfluorononanoic acid	<1.9	P4	1	ng/L		02/27/2022 11:02	005 BP3T1/2
Perfluorooctanesulfonic acid	<1.9	P4	1	ng/L	10	02/27/2022 11:02	005 BP3T1/2
Perfluorooctanoic acid	<1.9	P4	1	ng/L	10	02/27/2022 11:02	005 BP3T1/2
Surr: 13C2-PFDA (S)	100%	1		%REC		02/27/2022 11:02	005 BP3T1/2
Surr: 13C2-PFHxA (S)	97%	1		%REC		02/27/2022 11:02	005 BP3T1/2
Surr: HFPO-DAS (S)	95%	1		%REC		02/27/2022 11:02	005 BP3T1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205005
Client Sample ID.: N-07353

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 10:15 AM Point N-07353
 Received : 02/15/2022 01:23 PM Location Well 14
 Collected By CLIENT

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 02/15/2022 7:15 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/16/2022 1:15 PM	005 SP5T1/1
Total Coliforms	Absent		1		Absent	02/16/2022 1:15 PM	005 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205006
Client Sample ID.: NB-10/14

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 10:30 AM Point NB-10/14
 Received : 02/15/2022 01:23 PM Location Wells 10 & 14
 Collected By CLIENT Blended

<u>Analytical Method:</u> EPA 522		<u>Prep Method:</u> EPA 522			<u>Prep Date:</u> 02/16/2022 9:34 AM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,4-Dioxane (p-Dioxane)	1.1*		1	ug/L	1	02/16/2022 9:24 PM	006 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	92%		1	%REC		02/16/2022 9:24 PM	006 AG2R1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 03/01/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205007
Client Sample ID.: N-05654

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:50 AM Point N-05654
 Received : 02/15/2022 01:23 PM Location Well 11
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 02/16/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.58		1	ug/L	1	02/16/2022 9:41 PM	007 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	97%		1	%REC		02/16/2022 9:41 PM	007 AG2R1/2

Analytical Method: EPA 524.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,1-Dichloroethane	1.0		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,1-Dichloroethene	0.70		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Benzene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		02/26/2022 1:45 PM	007 VG9C1/2
Bromoform	<0.50		1	ug/L		02/26/2022 1:45 PM	007 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Chloroform	<0.50		1	ug/L		02/26/2022 1:45 PM	007 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205007
Client Sample ID.: N-05654

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:50 AM Point N-05654
 Received : 02/15/2022 01:23 PM Location Well 11
 Collected By CLIENT

Dibromochloromethane	<0.50	1	ug/L		02/26/2022 1:45 PM	007 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	02/26/2022 1:45 PM	007 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Styrene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Toluene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1	ug/L	80	02/26/2022 1:45 PM	007 VG9C1/2
Trichloroethene	0.82	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	02/26/2022 1:45 PM	007 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	02/26/2022 1:45 PM	007 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	108%	1	%REC		02/26/2022 1:45 PM	007 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	107%	1	%REC		02/26/2022 1:45 PM	007 VG9C1/2

Analytical Method: EPA 537.1

Prep Method: EPA 537.1

Prep Date: 02/23/2022 5:37 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.9	1		ng/L		02/27/2022 9:59 PM	007 BP3T1/2
Perfluoroheptanoic acid	<1.9	1		ng/L		02/27/2022 9:59 PM	007 BP3T1/2
Perfluorohexanesulfonic acid	<1.9	1		ng/L		02/27/2022 9:59 PM	007 BP3T1/2
Perfluorononanoic acid	<1.9	1		ng/L		02/27/2022 9:59 PM	007 BP3T1/2
Perfluorooctanesulfonic acid	<1.9	1		ng/L	10	02/27/2022 9:59 PM	007 BP3T1/2
Perfluorooctanoic acid	<1.9	1		ng/L	10	02/27/2022 9:59 PM	007 BP3T1/2
Surr: 13C2-PFDA (S)	98%	1		%REC		02/27/2022 9:59 PM	007 BP3T1/2
Surr: 13C2-PFHxA (S)	95%	1		%REC		02/27/2022 9:59 PM	007 BP3T1/2
Surr: HFPO-DAS (S)	95%	1		%REC		02/27/2022 9:59 PM	007 BP3T1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205007
Client Sample ID.: N-05654

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:50 AM Point N-05654
 Received : 02/15/2022 01:23 PM Location Well 11
 Collected By CLIENT

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 02/15/2022 7:15 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/16/2022 1:15 PM	007 SP5T1/1
Total Coliforms	Absent		1		Absent	02/16/2022 1:15 PM	007 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205008
Client Sample ID.: N-05655

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 11:15 AM Point N-05655
 Received : 02/15/2022 01:23 PM Location Well 12
 Collected By CLIENT

Sample Comments:
 RUN TO WASTE

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 02/16/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.28		1	ug/L	1	02/16/2022 9:59 PM	008 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	99%		1	%REC		02/16/2022 9:59 PM	008 AG2R1/2

Analytical Method: EPA 524.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,1-Dichloroethane	0.71		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Benzene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Bromoform	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205008
Client Sample ID.: N-05655

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 11:15 AM Point N-05655
 Received : 02/15/2022 01:23 PM Location Well 12
 Collected By CLIENT

Sample Comments:
 RUN TO WASTE

Compound	Concentration	Qualifier	D.F.	Units	Limit	Analyzed	Container
Chloroform	<0.50	1		ug/L		02/26/2022 1:19 PM	008 VG9C1/2
Chloromethane	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Dibromochloromethane	<0.50	1		ug/L		02/26/2022 1:19 PM	008 VG9C1/2
Dibromomethane	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Dichlorodifluoromethane	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Ethylbenzene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Methyl-tert-butyl ether	<0.50	1		ug/L	10	02/26/2022 1:19 PM	008 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Styrene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Toluene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1		ug/L	80	02/26/2022 1:19 PM	008 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	02/26/2022 1:19 PM	008 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	02/26/2022 1:19 PM	008 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	114%	1		%REC		02/26/2022 1:19 PM	008 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	104%	1		%REC		02/26/2022 1:19 PM	008 VG9C1/2

Analytical Method: EPA 537.1		Prep Method: EPA 537.1			Prep Date: 02/23/2022 5:37 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.9	P4	1	ng/L		02/27/2022 11:33	008 BP3T1/2
Perfluoroheptanoic acid	6.1	P4	1	ng/L		02/27/2022 11:33	008 BP3T1/2
Perfluorohexanesulfonic acid	8.8	P4	1	ng/L		02/27/2022 11:33	008 BP3T1/2
Perfluorononanoic acid	6.9	P4	1	ng/L		02/27/2022 11:33	008 BP3T1/2
Perfluorooctanesulfonic acid	13.6*	P4	1	ng/L	10	02/27/2022 11:33	008 BP3T1/2
Perfluorooctanoic acid	12.9*	P4	1	ng/L	10	02/27/2022 11:33	008 BP3T1/2
Surr: 13C2-PFDA (S)	99%		1	%REC		02/27/2022 11:33	008 BP3T1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Araci

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205008
Client Sample ID.: N-05655

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 11:15 AM Point N-05655
 Received : 02/15/2022 01:23 PM Location Well 12
 Collected By CLIENT

Sample Comments:
 RUN TO WASTE

Surr: 13C2-PFHxA (S)	98%	1	%REC	02/27/2022 11:33	008 BP3T1/2
Surr: HFPO-DAS (S)	95%	1	%REC	02/27/2022 11:33	008 BP3T1/2

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 02/15/2022 7:15 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/16/2022 1:15 PM	008 SP5T1/1
Total Coliforms	Absent		1		Absent	02/16/2022 1:15 PM	008 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205009
Client Sample ID.: N-08007

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:30 AM Point N-08007
 Received : 02/15/2022 01:23 PM Location Well 15
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 02/16/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.029		1	ug/L	1	02/16/2022 10:16	009 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	99%		1	%REC		02/16/2022 10:16	009 AG2R1/2

Analytical Method: EPA 524.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Benzene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		02/26/2022 2:10 PM	009 VG9C1/2
Bromoform	<0.50		1	ug/L		02/26/2022 2:10 PM	009 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Chloroform	<0.50		1	ug/L		02/26/2022 2:10 PM	009 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205009
Client Sample ID.: N-08007

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:30 AM Point N-08007
 Received : 02/15/2022 01:23 PM Location Well 15
 Collected By CLIENT

Dibromochloromethane	<0.50	1	ug/L		02/26/2022 2:10 PM	009 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	02/26/2022 2:10 PM	009 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Styrene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Toluene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1	ug/L	80	02/26/2022 2:10 PM	009 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	02/26/2022 2:10 PM	009 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	02/26/2022 2:10 PM	009 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	110%	1	%REC		02/26/2022 2:10 PM	009 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	105%	1	%REC		02/26/2022 2:10 PM	009 VG9C1/2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.8	1		ng/L		02/27/2022 9:43 PM	009 BP3T1/2
Perfluoroheptanoic acid	<1.8	1		ng/L		02/27/2022 9:43 PM	009 BP3T1/2
Perfluorohexanesulfonic acid	<1.8	1		ng/L		02/27/2022 9:43 PM	009 BP3T1/2
Perfluorononanoic acid	<1.8	1		ng/L		02/27/2022 9:43 PM	009 BP3T1/2
Perfluorooctanesulfonic acid	<1.8	1		ng/L	10	02/27/2022 9:43 PM	009 BP3T1/2
Perfluorooctanoic acid	<1.8	1		ng/L	10	02/27/2022 9:43 PM	009 BP3T1/2
Surr: 13C2-PFDA (S)	102%	1		%REC		02/27/2022 9:43 PM	009 BP3T1/2
Surr: 13C2-PFHxA (S)	101%	1		%REC		02/27/2022 9:43 PM	009 BP3T1/2
Surr: HFPO-DAS (S)	100%	1		%REC		02/27/2022 9:43 PM	009 BP3T1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205009
Client Sample ID.: N-08007

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:30 AM Point N-08007
 Received : 02/15/2022 01:23 PM Location Well 15
 Collected By CLIENT

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 02/15/2022 7:15 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/16/2022 1:15 PM	009 SP5T1/1
Total Coliforms	Absent		1		Absent	02/16/2022 1:15 PM	009 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205010
Client Sample ID.: N-10451

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:00 AM Point N-10451
 Received : 02/15/2022 01:23 PM Location Well 17
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 02/16/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.027		1	ug/L	1	02/16/2022 10:34	010 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	97%		1	%REC		02/16/2022 10:34	010 AG2R1/2

Analytical Method: EPA 524.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Benzene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		02/26/2022 2:36 PM	010 VG9C1/2
Bromoform	<0.50		1	ug/L		02/26/2022 2:36 PM	010 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Chloroform	<0.50		1	ug/L		02/26/2022 2:36 PM	010 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205010
Client Sample ID.: N-10451

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:00 AM Point N-10451
 Received : 02/15/2022 01:23 PM Location Well 17
 Collected By CLIENT

Dibromochloromethane	<0.50	1	ug/L		02/26/2022 2:36 PM	010 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	02/26/2022 2:36 PM	010 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Styrene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Toluene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1	ug/L	80	02/26/2022 2:36 PM	010 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	02/26/2022 2:36 PM	010 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	02/26/2022 2:36 PM	010 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	111%	1	%REC		02/26/2022 2:36 PM	010 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	111%	1	%REC		02/26/2022 2:36 PM	010 VG9C1/2

Analytical Method: EPA 537.1		Prep Method: EPA 537.1			Prep Date: 02/23/2022 5:37 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.8	P4	1	ng/L		02/27/2022 9:11 PM	010 BP3T1/2
Perfluoroheptanoic acid	<1.8	P4	1	ng/L		02/27/2022 9:11 PM	010 BP3T1/2
Perfluorohexanesulfonic acid	<1.8	P4	1	ng/L		02/27/2022 9:11 PM	010 BP3T1/2
Perfluorononanoic acid	<1.8	P4	1	ng/L		02/27/2022 9:11 PM	010 BP3T1/2
Perfluorooctanesulfonic acid	<1.8	P4	1	ng/L	10	02/27/2022 9:11 PM	010 BP3T1/2
Perfluorooctanoic acid	<1.8	P4	1	ng/L	10	02/27/2022 9:11 PM	010 BP3T1/2
Surr: 13C2-PFDA (S)	101%	1		%REC		02/27/2022 9:11 PM	010 BP3T1/2
Surr: 13C2-PFHxA (S)	100%	1		%REC		02/27/2022 9:11 PM	010 BP3T1/2
Surr: HFPO-DAS (S)	98%	1		%REC		02/27/2022 9:11 PM	010 BP3T1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205010
Client Sample ID.: N-10451

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:00 AM Point N-10451
 Received : 02/15/2022 01:23 PM Location Well 17
 Collected By CLIENT

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 02/15/2022 7:15 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/16/2022 1:15 PM	010 SP5T1/1
Total Coliforms	Absent		1		Absent	02/16/2022 1:15 PM	010 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205011
Client Sample ID.: N-13192

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:20 AM Point N-13192
 Received : 02/15/2022 01:23 PM Location Well 18
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 02/16/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.049		1	ug/L	1	02/16/2022 11:09	011 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	95%		1	%REC		02/16/2022 11:09	011 AG2R1/2

Analytical Method: EPA 524.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Benzene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		02/26/2022 3:02 PM	011 VG9C1/2
Bromoform	<0.50		1	ug/L		02/26/2022 3:02 PM	011 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Chloroform	<0.50		1	ug/L		02/26/2022 3:02 PM	011 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205011
Client Sample ID.: N-13192

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:20 AM Point N-13192
 Received : 02/15/2022 01:23 PM Location Well 18
 Collected By CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Dibromochloromethane	<0.50	1		ug/L		02/26/2022 3:02 PM	011 VG9C1/2
Dibromomethane	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Dichlorodifluoromethane	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Ethylbenzene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Methyl-tert-butyl ether	<0.50	1		ug/L	10	02/26/2022 3:02 PM	011 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Styrene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Toluene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1		ug/L	80	02/26/2022 3:02 PM	011 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	02/26/2022 3:02 PM	011 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	02/26/2022 3:02 PM	011 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	113%	1		%REC		02/26/2022 3:02 PM	011 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	108%	1		%REC		02/26/2022 3:02 PM	011 VG9C1/2

Analytical Method: EPA 537.1

Prep Method: EPA 537.1

Prep Date: 02/23/2022 5:37 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.8	P4	1	ng/L		02/27/2022 9:27 PM	011 BP3T1/2
Perfluoroheptanoic acid	2.0	P4	1	ng/L		02/27/2022 9:27 PM	011 BP3T1/2
Perfluorohexanesulfonic acid	<1.8	P4	1	ng/L		02/27/2022 9:27 PM	011 BP3T1/2
Perfluorononanoic acid	<1.8	P4	1	ng/L		02/27/2022 9:27 PM	011 BP3T1/2
Perfluorooctanesulfonic acid	3.1	P4	1	ng/L	10	02/27/2022 9:27 PM	011 BP3T1/2
Perfluorooctanoic acid	3.9	P4	1	ng/L	10	02/27/2022 9:27 PM	011 BP3T1/2
Surr: 13C2-PFDA (S)	94%	1		%REC		02/27/2022 9:27 PM	011 BP3T1/2
Surr: 13C2-PFHxA (S)	93%	1		%REC		02/27/2022 9:27 PM	011 BP3T1/2
Surr: HFPO-DAS (S)	95%	1		%REC		02/27/2022 9:27 PM	011 BP3T1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70204205011
Client Sample ID.: N-13192

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 02/15/2022 08:20 AM Point N-13192
 Received : 02/15/2022 01:23 PM Location Well 18
 Collected By CLIENT

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 02/15/2022 7:15 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/16/2022 1:15 PM	011 SP5T1/1
Total Coliforms	Absent		1		Absent	02/16/2022 1:15 PM	011 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :

70204205

Laboratory Certifications

Pace Analytical Services Ormond Beach

8 East Tower Circle, Ormond Beach, FL 32174
Alaska DEC- CS/UST/LUST
Alabama Certification #: 41320
Colorado Certification: FL NELAC Reciprocity
Connecticut Certification #: PH-0216
Delaware Certification: FL NELAC Reciprocity
Florida Certification #: E83079
Georgia Certification #: 955
Guam Certification: FL NELAC Reciprocity
Hawaii Certification: FL NELAC Reciprocity
Illinois Certification #: 200068
Indiana Certification: FL NELAC Reciprocity
Kansas Certification #: E-10383
Kentucky Certification #: 90050
Louisiana Certification #: FL NELAC Reciprocity
Louisiana Environmental Certificate #: 05007
Maine Certification #: FL01264
Maryland Certification: #346
Michigan Certification #: 9911
Mississippi Certification: FL NELAC Reciprocity
Missouri Certification #: 236
Montana Certification #: Cert 0074
Nebraska Certification: NE-OS-28-14
New Hampshire Certification #: 2958
New Jersey Certification #: FL022
New York Certification #: 11608
North Carolina Environmental Certificate #: 667
North Carolina Certification #: 12710
North Dakota Certification #: R-216
Ohio DEP 87780
Oklahoma Certification #: D9947
Pennsylvania Certification #: 68-00547
Puerto Rico Certification #: FL01264
South Carolina Certification: #96042001
Tennessee Certification #: TN02974
Texas Certification: FL NELAC Reciprocity
US Virgin Islands Certification: FL NELAC Reciprocity
Virginia Environmental Certification #: 460165
West Virginia Certification #: 9962C
Wisconsin Certification #: 399079670
Wyoming (EPA Region 8): FL NELAC Reciprocity

Pace Analytical Services Long Island



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
70204205

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987
New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Virginia Certification # 460302



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

WorkOrder :

70204205

Additional Qualifiers

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

WO#: 70204205



Sample Request Form PUBLIC WATER SUPPLIER

Date: 2/15/2022

Collected By: M. Prilgus

Accepted By: [Signature]

Cooler Temp: 4.0 °C
(W) 13:23 2/15/22

WELL OFF LINE _____

WELL RUN TO SYSTEM _____

YES NO VOC'S PRESERVED WITH HCl

Client Info:

Name or Code: Westbury Water Dist.

Address: _____

Phone #: _____

Attn: _____

Proj. # or (Name): _____

Bill To: _____

Copies To: _____

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
^{9:00 AM} 2-15-2022	GW	Well-9 N-02402	RW		RO		1,4 Dioxane PFOS/PFOA Poc/Mic	
^{9:25 AM} 2/15/22	GW	Well-16 N-08497	RW		RO		1,4 Dioxane PFOS/PFOA Poc/Mic	
^{9:35 AM} 2/15/22	PW	Wells 9/16 Blended EFF.	RW		RO	.91	1,4 Dioxane	
^{10:50 AM} 2/15/22	GW	Well-10 N-05007	RW		RO		1,4 Dioxane PFOS/PFOA Poc/Mic	
^{10:45 AM} 2/15/22	GW	Well-14 N-07353	RW		RO		1,4 Dioxane PFOS/PFOA Poc/Mic	
^{10:30 AM} 2/15/21	PW	Wells 10/14 Blended EFF.	RW		RO	.83	1,4 Dioxane	
^{8:50 AM} 2/15/22	GW	Well-11 N-05654	RW		RO		1,4 Dioxane PFOS/PFOA Poc/Mic	
^{11:15 AM} 2/15/22	GW	Well-12 N-05655	RW		RO		1,4 Dioxane PFOS/PFOA Poc/Mic	
^{8:30 AM} 2/15/22	GW	Well-15 N-08007	RW		RO		1,4 Dioxane PFOS/PFOA Poc/Mic	
^{8:00 AM} 2/15/22	GW	Well-17 N-10451	RW		RO		1,4 Dioxane PFOS/PFOA Poc/Mic	
^{8:20 AM} 2/15/22	GW	Well-18 N-13192	RW		RO		1,4 Dioxane PFOS/PFOA Poc/Mic	

Remarks:

Well-12 Ran to Waste



Sample Condition Upon Receipt

WO#: 70204205

Client Name: WWD

Project

PM: JSA

Due Date: 02/24/22

CLIENT: WWD

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No N/A

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091

Correction Factor: ±0.0

Cooler Temperature(°C): 4.0

Cooler Temperature Corrected(°C): 4.0

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: KW 2/15/22

Temperature Blank Present: Yes No

Type of Ice: Wet Blue None

Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer _____

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

				COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		5.
Short Hold Time Analysis (<72hr):	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		7.
Sufficient Volume: (Triple volume provided for I)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		12.
-Includes date/time/ID, Matrix: <u>SL WT OIL</u>				
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>ATC160347</u>				Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH-9 Sulfide, NAOH-12 Cyanide)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Exceptions: <u>VOA</u> , Coliform, TOC/DOC, Oil and Grease, DRO/8015 [water].				
Per Method, VOA pH is checked after analysis				Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot # _____				
Residual chlorine strips Lot # _____				
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	15. Positive for Sulfide? Y N
Lead Acetate Strips Lot # _____				
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____				

Client Notification/ Resolution: _____

Field Data Required? _____

Y / N

Person Contacted: _____

Date/Time: _____

Comments/ Resolution: _____



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70206529001
Client Sample ID.: N-05007

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 03/07/2022 08:55 AM Point N-05007
 Received : 03/07/2022 10:50 AM Location Well 10
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 03/10/2022 9:19 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.54	1		ug/L	1	03/10/2022 7:01 PM	001 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	91%		1	%REC		03/10/2022 7:01 PM	001 AG2R1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 03/13/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70206529002
Client Sample ID.: N-05654

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 03/07/2022 07:40 AM Point N-05654
 Received : 03/07/2022 10:50 AM Location Well 11
 Collected By CLIENT

<u>Analytical Method:</u> EPA 522		<u>Prep Method:</u> EPA 522			<u>Prep Date:</u> 03/10/2022 9:19 AM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,4-Dioxane (p-Dioxane)	0.029		1	ug/L	1	03/10/2022 7:17 PM	002 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	90%		1	%REC		03/10/2022 7:17 PM	002 AG2R1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 03/13/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70206529003
Client Sample ID.: N-07353

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 03/07/2022 09:05 AM Point N-07353
 Received : 03/07/2022 10:50 AM Location Well 14
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 03/10/2022 9:19 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	1.5*		1	ug/L	1	03/10/2022 7:33 PM	003 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	91%		1	%REC		03/10/2022 7:33 PM	003 AG2R1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 03/13/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Westbury Water & Fire Dist.
160 Drexel Ave.
Westbury, NY 11590

Lab No. : 70206529004
Client Sample ID.: N-08497

Attn To : Supt. Ingram
 Federal ID : 2902856
 Collected : 03/07/2022 08:20 AM Point N-08497
 Received : 03/07/2022 10:50 AM Location Well 16
 Collected By CLIENT

<u>Analytical Method:</u> EPA 522		<u>Prep Method:</u> EPA 522			<u>Prep Date:</u> 03/10/2022 9:19 AM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,4-Dioxane (p-Dioxane)	0.75		1	ug/L	1	03/10/2022 7:50 PM	004 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	92%		1	%REC		03/10/2022 7:50 PM	004 AG2R1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Jennifer Aracri

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 03/13/2022



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
70206529

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987
New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Virginia Certification # 460302

WO#: 70206529



70206529

Sample Request Form PUBLIC WATER SUPPLIER

Date: 3-7-2022

Collected By: McPherson

Accepted By: [Signature] 3/7/22 10:50

Cooler Temp: 51 °C

WELL OFF LINE _____

WELL RUN TO SYSTEM _____

YES NO VOC'S PRESERVED WITH HCl

Client Info:

Name or Code: Westbury Water Dist.

Address: _____

Phone #: _____

Attn: _____

Proj. # or (Name): _____

Bill To: _____

Copies To: _____

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings		Analysis	Lab No.
						Cl ₂	pH/Temp		
3-7-2022 ^{8:59 AM}	GW	Well-10 N-05007	RW		RO			1,4 Dioxane	
3/7/22 ^{7:40 AM}	GW	Well-11 N-05654	RW		RO				
3/7/22 ^{8:05 AM}	GW	Well-14 N-07353	RW		RO				
3/7/22 ^{8:20 AM}	GW	Well-16 N-05497	RW		RO				

Remarks: 1,4 Dioxane



Sample Condition Upon Receipt

WO#: 70206529

Client Name: WWD

Project: _____

PM: JSA

Due Date: 03/16/22

CLIENT: WWD

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No N/A

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091 Correction Factor: + 0.1

Cooler Temperature(°C): 5.1 Cooler Temperature Corrected(°C): 5.2

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: KW 3/16/22

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID, Matrix: <u>SL WT OIL</u>	
All containers needing preservation have been checked? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>HC160347</u>	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRD/8015 (water).	
Per Method, VOA pH is checked after analysis	Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot # _____	
Residual chlorine strips Lot # _____	Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sulfide? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Lead Acetate Strips Lot # _____	Positive for Sulfide? Y N
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____	

Client Notification/ Resolution: _____

Field Data Required? Y / N

Person Contacted: _____

Date/Time: _____

Comments/ Resolution: _____

* PM (Project Manager) review is documented electronically in LIMS.